PART V.

Tender for installing three 1 H.P. pumping sets (one for each well) at Government Stud Farm, Kunigal.

Sl. No.	Names of materials, etc.	Unit	Quantity	Rate	Amount
	Supplying and running mains and wiring the motor using No. 12 B. & S. insulated wire for 600 volts, 2,500 M.G. in $\frac{3}{4}$" G.I. pipe from the Government pole to the meter board and from there to the motor inside the well (for all the 3 wells). The pipe should be rigidly fixed to the stone lining of the well ..	R.ft.	200		
2	Supplying and fixing teakwood meter board 2′×2$\frac{1}{4}$′×3″ mounted with 15 amps. T.P.S.T. iron-clad switch with fuses, starter for 1 H.P. motor, with a pilot lamp with fuses and controlling switches for the lamps, and wired complete	Sets	3		
3	Supplying 1 H.P. motor 220/230 V, 25 cycles, 3 phase, directly coupled to a centrifugal pump with a foot value strainer complete with bed plate and fixing the same on the steel girders inside the well at a depth of 30′—35′ below the ground level (the girders or railings available at the top of the well will be supplied by the department for fixing the same inside the well)	Sets	3		
4	Supplying and fixing 1$\frac{1}{2}$″ G.I. pipe for suction and delivery for the above pumping set with bends, flanges, etc., complete (for all the 3 wells)	R.ft.	180		
5	Grounding the motor bed plates, pipe, switches, etc., complete	Sets.	3		
	Total ..				..

C. R. GOWDA,
Superintendent.

PRIVATE ADVERTISEMENTS.

GOVERNMENT OF MYSORE, STORES PURCHASE COMMITTEE, BANGALORE.

No. S. P. C. 28358-70, *dated 27th February* 1940.

To

The Firms dealing in Electrodes.

Enquiry No. 3930.

ELECTRODES REQUIRED FOR THE CENTRAL INDUSTRIAL WORKSHOP.

Dear Sir/GENTLEMEN,

Please be good enough to intimate your best prices and the earliest time of delivery for the materials described in the undermentioned schedule in the form printed below.

It should be distinctly understood that the acceptance by us of your quotation will be subject to the following conditions :—

Withdrawal from the quotation after it is accepted or failure to make the supply within the specified time or according to specifications will entail cancellations of the order and purchases being made at your expense from other sources in addition to the levy of a penalty of 3 per cent of the value of the order as and by way of liquidated damages. In such an event, the Stores Purchase Committee reserve the right to remove your name from the list of approved firms.

The quotations should be superscribed "Quotations for Electrodes" with the above enquiry number.

This enquiry will be closed on the 16th March 1940.

Schedule.

Item No.	Description of material offered	Quantity	Price quoted F. O. R.	Time of delivery
			Bangalore City.	
1	S.W.G. No. 10 gauge Electrodes	2,000 rods		
2	S.W.G. No. 12 gauge Electrodes	1,000 ,,		
3	S.W.G. No. 8 gauge Electrodes	1,000 ,,		

N.B.—The length in which the electrodes will be supplied and the type of electrodes offered should be clearly mentioned in the quotation.

Yours faithfully,
MIR SAFDAR HUSSAIN,
Secretary,
Stores Purchase Committee.